

**OFFICE OF THE  
LOGAN COUNTY ENGINEER  
P.O. BOX 427  
1991 COUNTY ROAD 13  
BELLEFONTAINE, OH 43311**

[www.lceo.us](http://www.lceo.us)

**SCOTT C. COLEMAN, P.E., P.S.  
LOGAN COUNTY ENGINEER**

**Telephone: (937) 592-2791**

**Fax: (937) 599-2658**

**Response to Questions #2**

**For Shape Ditch Project**

**Issued: November 8, 2021**

The following are responses to questions that our office has received via email with regards to the above mentioned project.

1. Q: Can a bid item for Mobilization be added?  
A: No.
2. Q: What does the RCP in the Plans stand for?  
A: Rock Channel Protection (Type B). Please see page 7 of the Plans for RCP Details.
3. Q: What does the Unit Bid Price of the 755-feet of Miscellaneous Tile Connections represent?  
A: Per the 'General Notes' of the Bid Package the 'Contractor [is] to locate, via aerial imagery, historical documents or other method, all existing field tile connections and tie said field connections into proposed drainage pipes'. The 755-feet quantity is the estimated linear length of the miscellaneous tile connections.

Respectfully,



Michael J. Kerns, P.E.

Assistant Engineer, Logan County Engineer's Office